

1. DESIGN STANDARD:

- 1.1 Provide cleanouts every ninety feet and at change of directions.
- 1.2 Cleanouts must be accessible.

2. PRODUCT STANDARD:

- 2.1 Use cast iron pipe and fittings throughout the building. Bell & Spigot with neoprene gaskets must be used below slab on grade and outside the building. No-hub pipe and fittings may be used above grade. PVC piping is not acceptable.

3. PERFORMANCE STANDARD:

- 3.1 Provide complete sanitary soil, waste, and vent piping system as required by Codes and as per recommendations of manufacturer.
- 3.2 Test in accordance with applicable Code.