

1. DESIGN STANDARD:

1.1 Provide a complete storm piping system as required by Code.

2. PRODUCT STANDARD:

2.1 Use cast iron pipe and fittings throughout the building. Bell & Spigot with neoprene gaskets must be used below slab on grade and outside the building. No-hub pipe and fittings may be used above grade.

2.2 PVC pipe and fittings with solvent cement joints where approved by Rice University.

2.3 No carbon steel pipe allowed.

3. PERFORMANCE STANDARD:

3.1 Install piping per manufacturer's recommendations.

3.2 Test in accordance with applicable Code. Coordinate all tests with Rice University's Project Manager.

3.3 Insulate pipe in areas recommended and approved by Rice University.