

1. DESIGN STANDARD:

1.1 Provide a complete gas piping system as required by Code.

2. PRODUCT STANDARD:

2.1 Use Schedule 40 black steel pipe with screwed fittings. Piping below grade must be wrapped. Copper is not acceptable.

2.2 Specify gas cocks in an easily accessible location, in each branch line, and at each individual piece of gas consuming equipment.

3. PERFORMANCE STANDARD:

3.1 Install per recommendations of manufacturer.

3.2 Test in accordance with applicable Code. Coordinate all tests with Rice University's Project Manager.