

1. PRODUCT STANDARD:

- 1.1 All wiring (including 10 AWG and smaller) shall be stranded copper.
- 1.2 Branch circuit wiring shall be #12 AWG, minimum.
- 1.3 Control circuit wiring shall be #14 AWG, minimum.
- 1.4 Insulation type indoors shall be THWN/THHN type. Insulation type outdoors shall be THWN or XHHW type.
- 1.5 In general, MC cable will not be allowed. On a case-by-case basis, stranded conductor type MC cable may be allowed in existing walls and for fixture whips. Coordinate use of MC cable with the Rice University's Project Manager.
- 1.6 Type AC cable (trade name BX) will not be allowed.