

1. DESIGN STANDARD:

1.1 Surge Protective Devices are required at building main switchboards, at distribution switchboards and at distribution panelboards.

2. PRODUCT STANDARD:

2.1 Surge Protective Devices are to be internal type at switchboards, external type at panelboards.