

2. PRODUCT STANDARD:

- 2.1 Standard must be written around G&W rotary puffer (RP style) vacuum interrupter.
- 2.2 For use with underground feeders, height of switch must be specified approximately 18” higher than standard in order to allow for proper bending radius of cables.
- 2.3 Specify dead front elbow type connectors.
- 2.4 Specify enclosure for vacuum interrupter where installed other than in electrical vaults. Where installed in electrical vaults, enclosure for vacuum interrupter is not required.