

1. DESIGN STANDARD:

- 1.1 Fuel tank to be sized for 24 hours of operation at full load.
- 1.2 Fuel tank to be UL 2085 type.
- 1.3 Discuss location of generator set (interior, exterior, exact location at building exterior) with Rice University Project Manager.

2. PRODUCT STANDARD:

- 2.1 Generator set motor to be Diesel type, not spark ignited.
- 2.2 Where generator set is located at building exterior, specify a quiet (sound attenuator) type enclosure. Silencer (muffler) to be located inside of the enclosure.